

OFFICE OF THE MUNICIPAL COMMISSIONER KHAMMAM

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

File No.KMC/A2/8230/2025

Dated: 10.05.2025

It is certified that an inspection team headed by VEMULA RANJITH REDDY, SUPERINTEND ENGINEER, DEPARTMENT OF PUBLIC AND HEALTH AND ENGINEERING DEPARTMENT FROM MUNICIPAL CORPORATION KHAMMAM.

Inspected the New Era School, H.No. 15-8-898/1, Radhakrishna Nagar, Khammam on 09.05.2025. and on the basis of Water Test Report (Attached) bearing no.007 dated 08.05.2025 of SVM Water Testing Lab (PHED Lab)certified that the New Era School has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 2 years from 10.05.2025.




10.5.25

Signature with Seal :

COMMISSIONER
MUNICIPAL CORPORATION
KHAMMAM.

Name : ABHISHEK AGUSTYA

Designation : COMMISSIONER


: MUNICIPAL CORPORATION KHAMMAM

To


I.V. Ramana Rao

Secretary & Correspondent

New Era School, Khammam

x 
PRINCIPAL
NEW ERA SCHOOL
KHAMMAM,

MANAGER


NEW ERA SCHOOL



TEST REPORT

SVM WATER TESTING LAB

OPP SRBGNR DEGREE COLLAGE
YELLANDU ROAD
KHAMMAM, 507002.

REGDNO:10457/2016
EMAIL: svmlabs@gmail.com
MOBILE NO: 7416103464

SAMPLE PARTICULARS :

COMPANY NAME : NEW ERA SCHOOL, MAMATHA ROAD,
TYPE OF WATER : BORE WATER ✓
QUANTITY : 1 LITER PET BOTTLE
MFD: 3/1/2017 : BATCH NO: 007

RECEIVED SAMPLE : 7/05/2025
COMPLETED TEST : 08/05/2025
SELF LIFE : 30 DAYS


SNO.	DESCRIPTION	ISI REFERENCE: 14543	PERMISSIBLE/LIMIT	RESULT
1	PH	IS3025(Pt.11)	6.5 to 8.5	7.32 ✓
2	Color	IS3025(Pt.4)	25 H.Unites	<3 H.Units
3	Odour	IS3025(Pt.5)	Agreeable	Agreeable
4	Taste	IS3025(Pt.8)	Agreeable	Agreeable
5	Turbidity	IS3025 (Pt.10)	10 NTU	5 NTU
6	Chloride	IS3025(Pt.32)	200 Mg/l	213 Mg/l
7	Sulphate	IS3025(Pt.24)	200 Mg/l	169 Mg/l
8	Alkalinity(Phen)	IS3025(Pt.23)	200 Mg/l	TRACE
9	Calcium (CA 2+)	IS3025(Pt.40)	75 Mg/l	92Mg/l ✓
10	TDS	IS3025(Pt.16)	2000 PPM	402PPM
11	Residual Free Chlorine	IS3025(Pt.26)	0.2 Mg/l	Nil
12	Hardness	IS3025(Pt.16)	155 Mg/l	231 Mg/l
13	Amonical nitrogen	---	---	Nil
14	flouride	---	1.0 Mg/l	0.92Mg/l
15	Alkalinity(methyl orange)	IS3025(Pt.16)	110Mg/l	219Mg/l
16	Mg2+		30Mg/l	72 mg/l


MICROBIOLOGY:-

Sl.No	Test Particulars	(MPN Count 1&2)
1	Esherichia Coli	ABSENT (two days) ✓
2	Coli Form	ABSENT (two days) ✓
3	Yeast & Mould Bacteria	ABSENT(5 days) ✓
4	Aerobic Microbial Count (Lessthan 100 CfU)at 22C	AW
	Aerobic Microbial Count (Lessthan 20 CfU) at 37C	AW


RESULT:-

According to above water analysis. PHYSICAL & CHEMICAL PARAMETERS ARE CONTROLLED.ISI
STANDARDS

X 
PRINCIPAL
NEW ERA SCHOOL
KHAMMAM.

MANAGER

NEW ERA SCHOOL

CHEMIST & MICROBIOLOGIST.



NEW ERA SCHOOL
MAMATHA ROAD
KHAMMAM, 507002

Authorised Male:
SVM WATER TESTING LAB
H.No: 15-13-1,
Opp: SR&BGNR Govt. Degree College
Ph: 7416103464, 9381218128



X *Anand*
PRINCIPAL
NEW ERA SCHOOL
KHAMMAM.

MANAGER

Bluesky

NEW ERA SCHOOL

